

SECTION 07410

5V-CRIMP - PREFORMED ROOF AND WALL PANELS

Specifier: Notation (#) means that text following is a specifier's note or sample.

PART 1 - GENERAL

1.01 Description

Specifier: Do not alter paragraph A. except by adding section title in parenthesis.

A. General

1. Furnish all labor, material, tools, equipment, and services for all preformed (# Choose one: roofing, fascia, siding, soffit, mansard) as indicated, in accord with provisions of Contract Documents.
2. Completely coordinate with work of all other trades.
3. Although such work is not specifically indicated, furnish and install all supplementary or miscellaneous items, appurtenances and devices incidental to or necessary for a sound, secure and complete installation.
4. See Division 1 for General Requirements.

B. Related work specified elsewhere:

1. Structural steel: Section 05100.
2. Steel joists: Section 05200 or 05400
3. Flashing and sheet metal: Section 07600.

Specifier: Delete references to sections not used and add any references to sections which are pertinent.

1.02 Quality Assurance

A. Applicable standards:

1. **SMACNA:** "Architectural Sheet Metal Manual" Sheet Metal and Air Conditioning Contractors National Association, Inc.
2. **AISC:** "Steel Construction Manual" American Institute of Steel Construction.
3. **AISI:** "Cold Form Steel Design Manual" American Iron and Steel Institute.
4. **ASTM A792-89:** Standard Specification for Steel Sheet, Aluminum-Zinc Alloy Coated by the Hot Dip Process, General Requirements
5. **ASTM A527-90:** Standard Specification for Steel Sheet, Zinc Coated (Galvanized) by the Hot-Dip Process, Lock-Forming Quality
6. **ASTM A526-90:** Standard Specification for Steel Sheet, Zinc, Coated (Galvanized) by the Hot-Dip Process, Commercial Quality.

General Overview

Architectural Exposed Fastener Panel

Applications: Residential and Agricultural

Features: Anti-siphon channel side lap design

Coverage: 24" Wide coverage, 7/16" height inverted v's

Slope: Minimum 3:12

Substrate: 24, 26, and 29 gauge Galvanized or Galvalume steel sheet

Finish Options: Available in Bare Galvanized, Bare Galvalume or SemCoat SP colors

A. Applicable standards, cont.:

7. **ASTM A446-91:** Standard Specification for Steel Sheet, Zinc Coated (Galvanized) by the Hot-Dip Process, Structural (Physical) Quality.
8. **ASTM B 117:** Salt spray testing of coating 1000 Hrs.
9. **ASTM G 23:** Accelerated testing of coating 2000 hrs.

B. Manufacturer's qualifications:

1. Manufacturer has a minimum of five years experience in manufacturing panels of this nature in a permanent, stationary, indoor production facility utilizing industrial equipment.
2. Manufacturer has current nationally recognized model building code agency product approvals for fastening design pressure capacities that meet projects uplift resistance test requirements per (UL 580 Class 90 or higher).
3. Manufacturer has an approved independent quality assurance inspection program to validate certified material and finished product specifications.
4. Manufacturer has permanent ink marking on panels that identifies the manufacturer, building code approvals, and date of production for material traceability and warranty validation.
5. Manufacturer's product is listed in the UL (Underwriters Laboratory) fire resistant directory.

C. Installer's qualifications:

1. Installation of panels and accessories by installers with a minimum of two years experience in panel projects of this nature.

1.03 Submittals

A. Shop drawings:

1. Submit complete shop drawings and erection details to Architect for review. Do not proceed with manufacture prior to review of shop drawings. Do not use drawings prepared by Architect for shop or erection drawings.
2. Shop drawings show methods of erection, elevations, and plans of roof panels, sections and details, anticipated loads, flashings, roof curbs, vents, sealants, interfaces with all materials not supplied and proposed identification of component parts and their finishes.

B. Samples:

1. Submit samples and color strips for all proposed finishes.
 - a. Submit one 12 in. long sample of panel.
 - b. Submit two 2 in round color chip samples in color selected by Architect.

C. Warranty(s):

1. Metal panel manufacturer, upon final acceptance for project, furnish a warranty covering bare metal against rupture, structural failure, and perforation due to normal atmospheric corrosion exposure for a period of twenty-five (25) years.
2. Covering panel finish against cracking, checking, blistering, peeling, flaking, chipping, chalking, and fading for a period of twenty-five (40) years.



1.04 Product Delivery, Storage and Handling

A. Delivery:

1. Deliver panels to job site properly packaged to provide protection against transportation damage.

B. Handling:

1. Exercise extreme care in unloading, storing, and erecting panels to prevent bending, warping, twisting, end and surface damage.

C. Storage:

1. Store all material and accessories above ground on well skidded platforms.
2. Store under waterproof covering. Provide proper ventilation to panels to prevent condensation buildup between each panel.

Specifier: Choose the appropriate "Part 2 - Products" section that applies. If more than one type (series) is used on a project, renumber as necessary.

PART 2 - PRODUCTS

(#5V-CRIMP Panel, minimum slope of 3:12, for roofing, mansard equipment screen)

2.01 Materials

A. Panel profile:

1. 7/16" height rib, 24" coverage width

B. Panel Style:

1. Sidelap seam
2. Exposed fastener

C. Gauge: (# choose one)

1. 24 gauge
2. 26 gauge
3. 29 gauge

D. Substrate (# choose one)

1. Galvalume steel sheet, AZ50, conforming to ASTM A792 for all panels
2. Galvanized steel sheet, G90, conforming to ASTM A446 for unpainted panels
3. Galvanized steel sheet, G60, conforming to ASTM A446 for painted panels

E. Texture:

1. Smooth

F. Finish: (# choose one)

1. Semcoat Superl siliconized polyester (# 40-year warranty, consult manufacturer for color and gauge availability)
2. Bare AZ-55 Acrylic Galvalume (# 25-year warranty, available in 24, 26 and 29 gauges)
3. Bare G-90 hot dipped Galvanized (# Available in 26 and 29 gauges)

G. Color:

1. Selected from manufacturer's standard line.

H. Acceptable manufacturer:

1. SOUTHEASTERN METALS MFG. CO., FL,GA,
(800) 874-0335

I. Option manufacturers:

1. DOT METAL PRODUCTS., TX
(800) 331-9966
2. CONSTRUCTION METALS, INC., CA
(800) 576-9810
3. WEATHER GUARD BUILDING PRODUCTS., CO
(800) 999-6240

Insert: Architect's method of approval of "or equals."

J. Other manufacturers desiring approval, comply with Section 01630.

2.02 Fabrication

- A. Roll form panels in continuous lengths, full length of detailed runs.
- B. Fabricate trim, flashing and accessories to detailed profiles.
- C. Fabricate trim and flashing from same material as panel.

PART 3 - EXECUTION

3.01 Surface Conditions

A. Inspection:

1. Inspect installed work of other trades and verify that such work is complete to a point where this work may continue.
2. Verify that installation may be made in accordance with approved shop drawings and manufacturer's instructions.

B. Discrepancies:

1. In event of discrepancy, notify Architect.
2. Do not proceed with installation until discrepancies have been resolved.

3.02 Installation

- A. Install panels so that they are weathertight, without waves, warps, buckles, fastening, stresses or distortion, allowing for expansion and contraction.
- B. Install panels in accordance with manufacturer's installation instructions and shop drawings.
- C. Provide concealed anchors at all panel attachment locations.
- D. Install panels plumb, level, and straight with seams and ribs/battens parallel, conforming to design as indicated.



3.03 Cleaning, Protection

- A. Dispose of excess materials and remove debris from site.
- B. Clean work in accordance with manufacturer's recommendations.
- C. Protect work against damage until final acceptance. Replace or repair to the satisfaction of the Architect, any work that becomes damaged prior to final acceptance.
- D. Touch up minor scratches and abrasions.
- E. At completion of each day's work and at work completion, sweep panels and flashing clean. Do not allow fasteners, cuttings, filings or scrapes to accumulate on finished surfaces.